

**Debbie Beadle**

---

**From:** R.Crispin <rcrispin1@yahoo.com>  
**Sent:** Thursday, December 06, 2012 6:26 PM  
**To:** ECA  
**Subject:** Re: ECA Public Hearing

One other item for Landslide Hazard Area:  
Change 20 ft to 30 ft in the exemption as seen below

SMC 21A.50.260 6) The following are exempt from the provisions of this section:  
(a) Slopes that are 40 percent or steeper with a vertical elevation change of up to ~~20~~ 30 feet if no adverse impact will result from the exemption based on the City's review of and concurrence with a soils report prepared by a licensed geologist or geotechnical engineer

**From:** R.Crispin <rcrispin1@yahoo.com>  
**To:** "eca@ci.sammamish.wa.us" <eca@ci.sammamish.wa.us>  
**Sent:** Thursday, December 6, 2012 6:15 PM  
**Subject:** ECA Public Hearing

See attachments:  
Frequently Flooded Areas.pdf  
Landslide Hazard Areas.pdf  
Appendix\_A - Steep Slope Structures.pdf

EXHIBIT NO. 279.